Adaptive PMU-based Distribution System State Estimation exploiting the Cloud-based IoT paradigm

Paolo Attilio Pegoraro, Alessio Meloni, Luigi Atzori, Paolo Castello, Sara Sulis
DIEE, University of Cagliari, Italy
{*paolo.pegoraro,alessio.meloni,l.atzori,paolo.castello,sara.sulis*}*@diee.unica.it*

arXiv:1606.09116v1 [cs.NI] 29 Jun 2016

***Abstract*—This paper presents an adaptive Distribution System State Estimation (DSSE) which relies on a Cloud-based IoT paradigm. The methodology is adaptive in terms of the rate of execution of the estimation process which varies depending on the indications of the distributed measurement system. The system is composed, in particular, of Phasor Measurement Units (PMUs). PMUs are virtualized with respect to the physical devices and the corresponding virtualizing modules run in the communication network edge (i.e. closer to the physical objects). PMUs are set at a higher measurement rate, while the estimation process works at a given slower rate, for example once per second, in normal operative conditions. A local decision algorithm implemented in the virtualized module, monitors the measured quantities in order to detect and address possible unexpected dynamics. In particular, different metrics can be applied: the variations and the trend of variation of the rms voltage values, but also the Rate Of Change Of Frequency (ROCOF) of the monitored signals can be used to trigger rate variation in the DSSE. In case dynamics are detected, the measurement data is sent to the DSSE at higher rates and the estimation process runs consequently on a finer time scale. In the considered system only application level entities are located in the Cloud, thus allowing to obtain a bandwidth-efficient and smart data transmission. The results obtained on a 13-bus systems prove the goodness of the proposed methodologies.**

***Index Terms*—Distribution System State Estimation, Phasor Measurement Units, variable Reporting Rate, Internet of Things**

I. Introduction

Typical Distribution Systems (DSs) are composed of a very high number of nodes, balanced and unbalanced lines and few measurement devices for the monitoring of the quantities of interest. The traditional topologies are open-loop (rare reconfiguration possibilities), with substantially radial or only weakly meshed structures. Nevertheless, DSs are evolving towards more complex and dynamic architectures. In particular, the growing presence of Distributed Energy Resources (DERs), including small-scale generators, often based on Renewable Energy Sources (RESs), electric vehicles (EVs), and new high-efficiency residential and commercial appliances is a crucial event in grids evolution [1].

The increasing quantities of DERs located throughout the DSs are drivers and challenges for the distribution business. However, for their own nature, most DERs work in a substantially unpredictable manner and may cause bi-directional power flows and voltage transient problems. Grid stability is based on inertia of large rotating machinery, but most *green* energy sources lack short-term inertia. They can create critical conditions (for example, local power surplus), and thus require the adoption of proper countermeasures. As a consequence, significant changes in DS operation are expected. Active Distribution Networks (ADNs) must be conceived, where the need for smarter monitoring systems, supporting safe operation of the network becomes more and more evident.

Safe operation depends on the accurate knowledge of the electrical quantities in the grid [2]. Specific solutions, for the so called Distribution System State Estimation (DSSE), are required for DSs. Several DSSE techniques were presented in the literature (see, for instance, [3]–[6]). It is worth noting that the DS monitoring process is made complex not only because of the scarcity of measurement devices but also due to the high number of nodes and the geographical extension of the networks in question. In this context, several challenges are still open and new monitoring and management solutions are required. They can be summarized as follows:

- DSSE methodologies able to efficiently treat the high number of nodes of the DSs;
- measurement devices providing a time tag stating the reference time of the measurement results;
- communication infrastructures tackling the problem of efficiently collecting and coordinating the measurement results.

As for the methodologies, all those recently proposed in the literature are designed to efficiently face the estimation process so that the computational time can be limited. Among them, in particular Multi Area SE (MASE) methods are intended to address the issue of the high number of nodes (see, for instance, [7]).

As for the instrumentation, the Phasor Measurement Units (PMUs) are assuming a key role in protection and control systems. They measure voltage and current synchronized phasors (synchrophasors), along with frequency and rate of change of frequency (ROCOF), at a high reporting rate and with really high accuracy with respect to traditional supervisory control and data acquisition (SCADA) systems. The IEEE Standard for PMUs was released in 2011 by means of two documents [8] and [9]. An amendment, released in 2014, [10], modifies or suspends some of the performance requirements specified in [8]. These Standards aim to help in measuring dynamic

© 2016 IEEE. The IEEE copyright notice applies.

signals that can occur in power systems. Several algorithms have been proposed in the literature to address challenges due to the difficulty of measuring such signals. In particular, it is possible to mention [11], presenting an algorithm that allows the requirements of both the performance classes introduced in [9] to be met.

New ADN operators' requirements call for the modernization of the ICT infrastructure or the creation of a new one. It is now necessary to collect and to process high volumes of data arriving from remote PMUs. Cloud-based solutions can solve the non-trivial tasks related to storage, real-time computation and optimization of a large amount of data as that generated in complex distribution systems. In this scenario, the Cloud ensures a reliable environment with massive computational and storage capabilities. Moreover, it can elastically react to critical scenarios in which the need of resources for state estimation increases at a fast pace when specific events take place, thus ensuring an appropriate amount of resources are dynamically set only in critical time intervals, which is important from an economic point of view. Last but not least, the use of the IoT-related concept of virtualization on top of a cloud infrastructure boosts reusability of gathered data and is both evolution- and future-proof, since sensed data are decoupled from the details of the physical objects thanks to the virtualization layer.

The aforementioned challenges are open and intense research activities are expected. Recently, communication infrastructures for the DSSE of active networks have been proposed, see for example [12]. However, at the distribution level, the variations of the signals during the operation can be impressively rapid and significant. For this reason, an infrastructure able to support flexible and scalable information access is a critical challenge. In this context, the paper presents a novel adaptive DSSE architecture based on virtualized PMUs and on Cloud-based IoT platform. The architecture is able to adapt the rate of the DSSE according to the decisions taken by properly distributed monitoring points. Several metrics can be applied to detect possible dynamics in the locally measured signals, but the underlying concepts appear to be attractive for a continuous monitoring of the network status that is also bandwidth-saving and computationally efficient. The validation of the method is performed on a small test system. In the following, the overall procedure is described and the results obtained on a 13-bus DS are presented and discussed.

II. Background

A. Distribution System state Estimation

DSSE is in charge of estimating the state of the network, in terms of node voltages or branch currents, starting from a few heterogeneous instruments, which measure several electrical quantities with different accuracies and reporting rates. The aim is to obtain a reliable picture of the network status so that the grid can be safely operated, because the accuracy of the measurement results is decisive for downstream decisions. However, due to the lack of a sufficient number of measurement devices on the field, knowledge obtained from a priori information has to be added to the measurements to make the system observable. This prior information is commonly referred to as pseudo-measurements in power systems literature. As aforementioned, several methods for the DSSE have been presented in the literature, mostly based on a weighted least squares (WLSs) formulation. In particular, recently, a new branch current DSSE (BC-DSSE) was proposed [6], proving the same accuracy, but faster execution, as node voltage DSSE (NV-DSSE). To achieve an accurate knowledge of the network state, attention must be paid to the proper modeling of all the estimation problem elements. In addition, a detailed description of the measurement model is needed [13] and possible correlation existing in the measurements should be duly considered [14].

Fast procedures can be able to properly use the high rate of PMUs measurements. The full rate permits to have an up-to-date DSSE describing the dynamic of the system with the maximum resolution. This poses two main challenges. First of all, great computation flexibility is necessary, since estimations could pass from one every few seconds, as in SCADA systems, to one every $20\,\text{ms}$. Secondly, sending 50, or more, measurement messages of at least 70 bytes (only considering payload in simple PMU configurations) from a single device could easily become an issue both for the communication and for the data storage, when economic and logistic constraints are present.

Nevertheless, in normal operating conditions, DSs usually present near-steady-state signals. For this reason an adaptive estimation process can address the goal of efficiently monitor the network only in case of events.

B. Phasor Measurement Units

The PMUs were introduced in the late 1980s. The last version of the Standard was released in December 2011, presenting two parts: the C37.118-1 [8], dealing with the phasor estimation processes, and the C37.118-2 [9] dealing with the communications protocol. The Standard [8] defines two performance classes, P and M, for protection and monitoring-oriented applications, respectively. The P-class is intended for applications requiring fast measurement response time, especially protections in power system, while the M-class should be considered for the case where measurement accuracy is of crucial importance. A standard compliant PMU should meet all the requirements at least for one class. The main differences between the two performance classes are the test conditions for steady state performance and the requirements for dynamic performance, especially as far as frequency and ROCOF estimation are concerned.

The Standard [9] introduces a method for real-time exchange of synchronized phasor measurement data between power system equipment. A messaging protocol that can be used with any suitable communication protocol for real-time communication between PMU, phasor data concentrators (PDC), and other applications is introduced. All the data provided by PMUs must be aligned by the PDC by means of the time-tag included in the measures, to create a correlation

between measures made in the same time but from different measurement points of the network. The collected data can be stored for future analysis or used for real time application. In the latter case, the performance in terms of the latency and the bandwidth of the communication network are not negligible. The Standard [9] shows an example of the hierarchy in the synchrophasor network where the PMUs are connected to an local PDC, generally near or in the substation and the data are aggregated and sent to a next level of the data collection network as a corporate PDC or super PDC [15] to aggregate data across the utilities.

Required PMU reporting rates are: 10, 25, 50 frames/s for 50 Hz systems. The actual rate shall be user selectable. Support for other reporting modes is permissible, and higher rates such as 100 or 120 frames/s and rates lower than 10 frames/s (such as 1 frame/s) are encouraged by the Standard. A proper use of such different reporting rates can significantly improve the efficiency of the monitoring process.

C. Cloud IoT systems

The IoT paradigm has been evolving towards the creation of a cyber-physical world where everything can be found, activated, probed, interconnected, and updated, so that any possible interaction, both virtual and/or physical, can take place.



Fig. 1. Monitoring System Overview

A crucial concept in this paradigm is the virtual object (VO), which is the digital counterpart of any real entity in the IoT. It has now become a major component of the current IoT platforms, supporting the discovery and mash up of services, fostering the creation of complex applications, improving the objects energy management efficiency, as well as addressing heterogeneity and scalability issues. Indeed, virtualization has the ability to: make heterogeneous objects interoperable through the use of semantic descriptions; enable them to acquire, analyse and interpret information about their context in order to take relevant decisions and act upon the virtual objects. Moreover, it enhances existing functionalities in the IoT promoting the creation of new addressing schemes, improving the objects mobility management efficiency, as well as addressing accounting and authentication issues.

In addition, IoT platforms are more and more deployed in the cloud, as this approach allows for improving reliability, mash up of services, always on availability, elastic processing and memory resource provisioning. These features combined with the previously mentioned ones, make the virtualization and cloud computing the vital technologies for the future IoT solutions. In this paper, an IoT platform, namely Lysis (http://developers.lysis-iot.com/), has been implemented following the mentioned principles [16].

III. Adaptive Distribution System State Estimation Architecture

This paper presents an adaptive DSSE that is IoT based (the architecture scheme is in Fig.1). Close to the physical measurement devices, proper Virtual Objects (VOs) have been designed. A VO is defined as an entity that virtualizes device capabilities, so that any application can access or request its resources and functionalities in a reusable way, without knowing about the means (communications protocols and hardware primitives) that are needed to physically reach and retrieve information from the physical object.

In [9] the commands, for the data collector, to control the streams of data provided by PMUs are defined. However, the functionalities are limited to enable and disable the real time stream. In this paper, the possibility to change the rate of the reporting of the measurements, between VO and the Cloud, is designed in order to save the bandwidth of the network while using the high reporting rate provided by the PMU only when is necessary.

A distributed logic has been applied so that the DS monitoring can be adapted to possible events in the operating conditions. The monitoring reporting rate must increase when a dynamic in the DS is detected, whereas the rate must decrease when the event has lapsed.

A. Virtualized PMUs

The considered measurement system is constituted PMUs (real PMU prototypes are exploited). PMU measurements are sent with a GPS-synchronized timestamp to corresponding VOs, which are virtual containers implemented at the edge of the communication network. In our case, physical objects create a socket with the VO and send measured data according to [9]. VOs are able to communicate with the Cloud at a given Reporting Rate (RR) and report only necessary information using REST APIs and the JSON format, thus abstracting from the PMU standard. Communications can either take place in GET or $PUSH$ mode, which means that data can either be asked to the VO with a HTTP GET query or be sent automatically to a given location through HTTP POSTs. In the latter case, an appropriate trigger is set in the VO. In this paper, on the basis of the specific characteristics of the DSSE

application considered, the focus will be on the case of an automatic HTTP POST.

As to the creation and deployment of the VOs, Lysis platform approach, hosted in the Cloud, is followed [16]. It contains various VO templates each corresponding to a specific physical device. In our specific case, a number of templates are present corresponding to different physical PMUs (e.g. PMUs using different protocols such as IEEE 1344-95, IEEE C.37-118-2005, IEEE C.37-118.2-2011), since a different abstraction layer with the physical object is needed. Once the right interface is selected and the address of the VO location is given, the template is deployed in order to enable communication of the PMU with the applications implemented in the Cloud. This procedure, ensures the correctness of the VO setup and automates the procedure linked to the installation of new PMUs in the distribution network. It is important to highlight that the VOs are processes running at the communication network edge, so as to be close to the physical device.

B. Local process points

Each PMU sends its measurements to the corresponding VO, which is a sort of gateway with context-awareness capabilities working as a protocol adapter and receiving data every 20ms, that is at the maximum reporting rate suggested by [8]. Thanks to context-awareness capabilities, VOs can perform proper processing in order to extract information on the state of the part of DS which is directly measured. In particular, the VO is able to adapt its output reporting rate towards the application, following a fixed policy for all the VOs in the network (but easily reconfigurable also on a per-VO basis).

For the aim of this paper (as an example of detection methods of immediate understanding) the VO rate can be changed according to the monitoring of the following metrics with respect to given thresholds:

- the variation of RMS voltages between two consecutive input measurements (PMU measurements), α;
- the variation of RMS voltages between two consecutive output measurements (VO measurements), β;
- the ROCOF value for each input measurement, γ;

Each of them can be used to command both the increase of the estimation rate and the decrease, according to the desired monitoring process.

C. Adaptive DSSE rate

The DSSE application is performed in the cloud at the application level [1] using the measurements received, at varying reporting rate, from the different VOs. By default, the output rate of the VO (and thus of the DSSE) follows a low reporting rate. The measurements (with the corresponding timestamps), originated by the PMUs can, depending on the locally detected events, reach the DSSE at different rates (i.e. 50, 25, 10 and 1 frames/s). For this reason, the DSSE function is performed coordinating them at the highest reporting rate among the different measurement flows. As a consequence, a higher VO rate triggers a higher DSSE update rate, thus allowing to follow more accurately a faster event, even at nodes that are not directly monitored.

In this paper, the DSSE is performed using the fast branch-current state technique presented in [6], exploiting the linearization of power injection pseudo-measurements to obtain a constant Gain matrix in WLS computation. Nevertheless, it is worth noting that the adaptive architecture can be used for different estimation methodologies, without significant differences.

[1]With application level, we refer to the highest level of an IoT architecture as described in [17]

IV. Tests and Results

A. Test System

The electric system used in the tests is composed by a sample of a DS derived from the IEEE 13-bus (Fig.2). The IEEE 13 bus radial distribution test feeder [18] was proposed as a benchmark for the analysis of harmonic propagation in unbalanced networks. For the purposes of this study, the topology and the loads of this network were considered as a starting point to design a simplified test network suitable for the proposed architecture. In particular, the grid used for the test is, for the sake of simplicity, a totally balanced version of the IEEE 13 bus. In addition, a distributed generator was collocated on the network, at the node 34, so that presence of DER can be taken into account.



Fig. 2. Test system

The implementation of the network was carried out with the PSCAD/EMTDC software [19], a well known design and simulation tool to model power systems, acting as a graphical user interface to the EMTDC simulation engine. The tool allowed the simulation of different events and dynamics, at different locations.

B. Monitoring System

For a realistic measurement scenario, two PMUs were placed in two points of common coupling of the network. In particular, phasor voltages at nodes 31 and 71 are measured and the synchrophasors are computed, along with frequencies and ROCOFs.

Each PMU prototype is implemented using the real-time embedded controller NI-cRIO (Fig.3). The system is a reconfigurable device and, in the adopted configuration, is composed by a real-time controller NI-9014, a Field Programmable Gate Array (FPGA) module embedded in a chassis NI-9113, a NI 9215 16-Bit Simultaneous Analog Input Module, and a time synchronization module NI-9467. The time synchronization module is a GPS receiver that offers an accurate time source (accuracy $\pm$ 100 ns) to synchronize the embedded clock of the FPGA module and to provide the Coordinated Universal Time (UTC) to the real time controller. For this reason, every sample acquired by the PMU can be tagged directly at FPGA level with the UTC timestamp while the real-time controller is in charge of higher level phasor, frequency and ROCOF computations, and of the data frame encapsulation and transmission.



Fig. 3. PMU Prototype

The PMUs are configured to run the fast P-class estimation algorithm proposed in [20] at 50 frames/s. P-class algorithm has been chosen because it is faster to react to dynamic conditions and because its accuracy and latency characteristics do not change with reporting rate.

For the aim of this paper, two PMU prototypes, synchronized by means of GPS, are modified to compute synchronized measurements on the pre-stored test signals obtained by PSCAD simulations and corrupted by a level of noise of 70 dB, corresponding to a possible noise level of the data acquisition stage.

The computed synchrophasors are sent in real-time following the IEEE C37.118.2 message format.

As example of decision-making process at each input measurement message, the VO checks:

- if $\alpha > 2\%$;
- if $\beta > 2\%$
- if $\gamma > 5$ Hz/s

to decide whether to increase the output rate to the maximum rate, i.e. $RR = 50$ frames/s. Furthermore, the VO monitors if β drops below $0.1\,\%$ to slow down the RR progressively, and with a given inertia, to $25, 10, 1$ frames/s. A PMU, in general, is characterized by its measurement accuracies in presence of steady-state and dynamic conditions and this is the reason why different thresholds have been used for RR variations, keeping into account the device accuracies.

In the considered scenario, the state estimation, whose speed is changed when certain events are triggered on a node, can be compared with the DSSE outputs at a fixed rate, that is the most simple case, relying on simple and constant PMU configuration.

C. Results

In order to test the dynamics of the measurement system, several events have been generated and measured on the network.

In particular, for the sake of simplicity, the results concerning some possible operations on two loads are reported. The events are triggered in given moments of the operation of the network:

- breaker at node 75 opens at 13.5 s and closes at 15.5 s;
- breaker at node 150 opens at 8.2 s and closes at 17.6 s.

Meanwhile PMUs are continuously monitoring, measurements are collected by the corresponding VOs and then VOs check the aforementioned metrics. Each VO is expected to detect variations that affects the monitored voltage.



Fig. 4. RMS voltage estimation for node 71 evaluated with Adaptive DSSE.

Fig. 4 shows, for instance, the results obtained at node 71. The adaptive DSSE results are indicated by red dots. The measurements sent by the VO are represented by green "x" and the DSSE results at the constant reporting rate $RR = 50$ frames/s are also reported to serve as comparison. For the sake of clarity, a continuous blue line is used to connect the thin grid points obtained on the 20 ms resolution scale.

The actual reporting rate clearly follows the dynamic of the RMS voltage and the VO correctly detects the fast transient (a breaker opened), thus triggering the DSSE to take frequent snapshots of the network status, only when a interesting phenomenon is under investigation. Furthermore, the dynamics due to the other breaker operating on the other load and the reclosing of the breaker are correctly identified.

Fig. 5 reports the results of the DSSE in terms of the RMS voltage estimation at node 150 (that is not directly monitored) when both the maximum RR given by PMUs and the Adaptive DSSE are used. The disconnection of the load leads to an increase of node voltage amplitude: the DSSE promptly reacts to such event and is able to follow the dynamic



Fig. 5. RMS voltage estimation for node 150 evaluated with Adaptive DSSE.

of the unmonitored node thank to the adaptive policy of VOs and to the variable DSSE reporting rate.

V. Conclusions

This paper presents an auto adaptive distributed system state estimation in an IoT cloud-based system. The methodology is adaptive in the rate of execution of the estimation process. The rate varies depending on the indications of the PMU measurement system. The major features are: the virtualization of the PMUs with the virtual objects running on the edge of the communications network and the implementation of a logic at the virtual object so that the transmission rate of the measurements and the estimation process can be adapted on the basis of given metrics. The performance analysis were conducted in an example distribution network derived from the IEEE 13-bus. The obtained results prove the goodness of the methodology with accurate tracking of the events occurring in the network along with an efficient management of the transmission rate compared with the case of a full rate monitoring architecture.

Acknowledgement

This work has been supported by Regione Autonoma della Sardegna, L.R. 7/2007: Promozione della ricerca scientifica e dell'innovazione tecnologica in Sardegna, annualità 2012, CRP-60511".

References

[1] G. Heydt, "The next generation of power distribution systems," *IEEE Trans. Smart Grid*, vol. 1, no. 3, pp. 225–235, Dec. 2010.

[2] G. Celli, P. A. Pegoraro, F. Pilo, G. Pisano, and S. Sulis, "DMS cyber-physical simulation for assessing the impact of state estimation and communication media in smart grid operation," *IEEE Trans. Power Syst.*, vol. 29, no. 5, pp. 2436–2446, Sep. 2014.

[3] M. E. Baran and A. W. Kelley, "State estimation for real-time monitoring of distribution systems," *IEEE Trans. Power Syst.*, vol. 9, no. 3, pp. 1601–1609, Aug. 1994.

[4] W. M. Lin and J. H. Teng, "Distribution fast decoupled state estimation by measurement pairing," *Generation, Transmission and Distribution, IEE Proceedings-*, vol. 143, no. 1, pp. 43–48, Jan. 1996.

[5] H. Wang and N. Schulz, "A revised branch current-based distribution system state estimation algorithm and meter placement impact," *IEEE Trans. Power Syst.*, vol. 19, no. 1, pp. 207–213, Feb. 2004.

[6] M. Pau, P. A. Pegoraro, and S. Sulis, "Efficient branch-current-based distribution system state estimation including synchronized measurements," *IEEE Trans. Instrum. Meas.*, vol. 62, no. 9, pp. 2419–2429, Sep. 2013.

[7] C. Muscas, M. Pau, P. A. Pegoraro, S. Sulis, F. Ponci, and A. Monti, "Multiarea distribution system state estimation," *IEEE Trans. Instrum. Meas.*, vol. 64, no. 5, pp. 1140–1148, May 2015.

[8] *IEEE Standard for Synchrophasor Measurements for Power Systems*, IEEE Std C37.118.1-2011 (Revision of IEEE Std C37.118-2005), Dec. 2011.

[9] *IEEE Standard for Synchrophasor Data Transfer for Power Systems*, IEEE Std C37.118.2-2011 (Revision of IEEE Std C37.118-2005), Dec. 2011.

[10] *IEEE Standard for Synchrophasor Measurements for Power Systems – Amendment 1: Modification of Selected Performance Requirements*, IEEE Std C37.118.1a-2014 (Amendment to IEEE Std C37.118.1-2011), Apr. 2014.

[11] P. Castello, J. Liu, C. Muscas, P. A. Pegoraro, F. Ponci, and A. Monti, "A fast and accurate pmu algorithm for P+M class measurement of synchrophasor and frequency," *IEEE Trans. Instrum. Meas.*, vol. 63, no. 12, pp. 2837–2845, Dec. 2014.

[12] W. K. Chai, N. Wang, K. Katsaros, G. Kamel, G. Pavlou, S. Melis, M. Hoefling, B. Vieira, P. Romano, S. Sarri, T. Tesfay, B. Yang, F. Heimgaertner, M. Pignati, M. Paolone, M. Menth, E. Poll, M. Mampaey, H. Bontius, and C. Develder, "An information-centric communication infrastructure for real-time state estimation of active distribution networks," *IEEE Trans. Smart Grid*, vol. 6, no. 4, pp. 2134–2146, Jul. 2015.

[13] M. Asprou, E. Kyriakides, and M. Albu, "The effect of variable weights in a wls state estimator considering instrument transformer uncertainties," *IEEE Trans. Instrum. Meas.*, vol. 63, no. 6, pp. 1484–1495, Jun. 2014.

[14] C. Muscas, M. Pau, P. A. Pegoraro, and S. Sulis, "Effects of measurements and pseudomeasurements correlation in distribution system state estimation," *IEEE Trans. Instrum. Meas.*, vol. 63, no. 12, pp. 2813–2823, Dec. 2014.

[15] P. Myrda and K. Koellner, "Naspinet - the internet for synchrophasors," in *System Sciences (HICSS), 2010 43rd Hawaii International Conference on*, Jan. 2010, pp. 1–6.

[16] R. Girau, S. Martis, and L. Atzori, "A cloud-based platform of the social internet of things," in *EAI International Conference on Cyber PhysicaL Systems, IoTT and Sensors Networks*, Oct. 2015.

[17] L. Atzori, A. Iera, and G. Morabito, "The internet of things: A survey," *Computer Networks*, vol. 54, no. 15, pp. 2787 – 2805, 2010.

[18] R. Burch, G. Chang, M. Grady, E. Gunther, M. Halpin, Y. Liu, M. Marz, T. Ortmeyer, V. Rajagopalan, S. Ranade, P. Ribeiro, T. Sim, and W. Xu, "Test systems for harmonics modeling and simulation," *IEEE Trans. Power Del.*, vol. 14, no. 2, pp. 579–587, Apr. 1999.

[19] Monitoba. Pscad. [Online]. Available: https://hvdc.ca/pscad/

[20] P. Castello, P. Ferrari, A. Flammini, C. Muscas, P. A. Pegoraro, and S. Rinaldi, "A distributed PMU for electrical substations with wireless redundant process bus," *IEEE Trans. Instrum. Meas.*, vol. 64, no. 5, pp. 1149–1157, May 2015.